

Addendum 2 for RFB946300-01

Project Name: WRC Birches Window Replacement
DAS RFB #: 946300-01
DAS Project #: 9463.00
Date: 7/15/2025

Questions Due: July 14, 2025, at 10:00am

Bids Due: July 24, 2025, at 2:00pm

TO: PROSPECTIVE BIDDERS:

THIS ADDENDUM FORMS A PART OF THE BIDDING AND CONTRACT DOCUMENTS AND MODIFIES THE BIDDING DOCUMENTS DATED 06-19-2025, WITH AMENDMENTS AND ADDITIONS NOTED BELOW. THIS ADDENDUM SUPERSEDES AND SUPPLEMENTS ALL PORTIONS OF THE ORIGINAL BIDDING AND CONTRACT DOCUMENTS WITH WHICH IT CONFLICTS. ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE IMPACS ELECTRONIC PROCUREMENT SYSTEM. FAILURE TO DO SO MAY DISQUALIFY THE BIDDER.

GENERAL NOTES

Clarification: Window Types H, I, M, and N are wide openings with three fixed units. Addendum #1 clarified the need to install vertical mullion trim on the inside and exterior. Note that due to the opening sizes, these rough openings may require that vertical stiffener bars or plates are installed. Provide 2-way or 4-way stiffener bars with end plates as recommended by the manufacturer to meet wind performance requirements. Per Section 08 5200 Paragraph 2.4.D, "Provide mullions and cover plates capable of withstanding design wind loads of window units."

QUESTIONS AND ANSWERS

Q1. What is the engineers estimate for the project (includes both bid packages)?

A1. \$1,287,300.00

SUBSTITUTION REQUESTS:

- 08 5200 Alum Clad Wood Windows – Manuf.: Quaker Windows, Brighton Series - Approved

CHANGES TO SPECIFICATIONS AND DRAWINGS

SPECIFICATIONS:

- NONE

DRAWINGS:

- NONE

ATTACHMENTS

- NONE

END OF ADDENDUM