

## **Addendum #02 for RFQ #0919335008**

Project Name: State Hygienic Laboratory-Ankeny Fume Hood Install and Replacement

DAS RFQ #: 0919335008

DAS Project #: 9031.00

Date: 08/28/2018

Addendum #2:

- Cover Page – Table of Contents, Clarifications, Revision (1 page)

Clarifications:

1. Due date for quotes remains on **Thursday, August 30, 2018 at 2:00 PM.**

Revisions:

1. **REVISE** Section 011200 1.09 3 a. to read:

It will be the responsibility of this contractor to complete all demolition and disposal of the existing ductwork, casework and fixtures as shown on drawings. Disposal of the existing fume hood will be the responsibility of this contractor, but the demolition of the fume hood will be by others. The contractor should be aware the following chemicals are used in the labs and may have come in contact with the equipment to be demolished:

- 1) 3N HCL in n-butanol
- 2) Methanol
- 3) Acetonitrile
- 4) Formic acid

**END OF ADDENDUM #2**