



Addendum 03 for RFB937400-01

Project Name: HHS CHMHI Gym Ceiling Repair
DAS RFB #: 937400-01
DAS Project #: 9374.00
Date: 10/29/2024

Bids Due: October 31st, 2024 at 2:00 PM CST

Contents:

- Cover Page – Table of Contents Questions (1 pages)

1. Questions:

Q: Use blown insulation in lieu of batt insulation for Alt #1.

A: Yes, see changes below

Please make the following corrections or changes to the bidding documents. These items shall supersede, modify and/or change all statements or drawings to the contrary in the plans and specifications and shall take precedence over these documents. Bidders shall base their bid on the plans and specifications as modified by the changes herein specified.

REFER TO THE SPECIFICATIONS:

ITEM 1. Section 07 2100 Thermal Insulation. Delete paragraph 2.2. and replace with section 2.2 below. Delete paragraph 3.1.D. and replace with the paragraph below. Delete section 3.2.

2.2 LOOSE-FILL INSULATION

- A. Cellulosic-Fiber Loose-Fill Insulation: ASTM C 739, chemically treated for flame-resistance, processing, and handling characteristics. Provide R-25 in 8 inch (or equivalent for R value) settled thickness.

3.1 INSTALLATION, GENERAL

4. Place loose-fill insulation into spaces indicated, by machine blowing, to comply with ASTM C 1015. Level horizontal applications to uniform thickness as indicated, lightly settle to uniform density, but do not compact excessively.