

## **Addendum 1 for RFP942400-01**

Project Name: HHS STS Main Electrical Loop Revisions

RFP #: 942400-01

DAS Project #: 9424.00

Date: 6/25/2024

### **Proposals Due: July 11, 2024 @ 2pm**

1. The Pre-Proposal meeting on Thursday June 27, 2024 @ 1 pm will be held onsite at the Administration Building at 3211 Edgington Avenue, Eldora, IA 50627 or a call-in option will be available on Google Meet
  - a. [meet.google.com/cih-qtvb-pgu](https://meet.google.com/cih-qtvb-pgu) OR Join by phone (US) [+1 347-767-2865](tel:+13477672865) PIN: 906669985
  
2. QUESTIONS/CLARIFICATIONS
  - Q1. What voltage is the distribution system?
    - A1. The main loop is 15 kV.
  
  - Q2. What drawings are available?
    - A2. There are PDF drawings from a 2002 electrical upgrade project that added a generator, a PDF schematic drawing of the main loop from Alliant Energy, and CADD drawings for the site that show the electrical and other utilities that will be provided to the selected designer. The selected designer must still verify all information.