

ADDENDUM #2

Project Name:

NCF Building H (Main Server) and Master Control HVAC Replacement

DAS#9319.00

RFP931900-01

Addendum #2

Dated: February 3, 2023

This Addendum forms a part of the Request for Proposal documents. This Addendum supersedes and supplements all portions of the original Request for Proposal dated January 16, 2023, with which it conflicts.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE REQUEST FOR PROPOSAL. FAILURE TO DO SO MAY SUBJECT TO DISQUALIFICATION.

1. **Schedule** – Proposal date does not change.
2. **Questions:**
 - a. Q. What is the construction budget? *A. Estimated bid day estimate is \$400,000.00*
 - b. Q. How will the work of redesigning the ductwork inside of the master control room be handled in this project? Is it a bid alternate or a separate project? *A. Ductwork serving the inside of the master control room and server room should be considered as part of this project and not a bid alternate or separate project.*
 - c. Q. Can you confirm that the units are fully redundant and only one is needed during normal operation? *A. Yes, each unit shall be sized is to serve the master control room and server room independently and operate on a lead/lag schedule.*
3. **Attachments:**
 - a. RFP Pre-Proposal meeting sign in sheet.

END OF ADDENDUM

