

# ADDENDUM NO. 1

Date: August 24, 2018

Project: State Training School

Corbett-Miller Door Control DAS RFB 0919335005 DAS Project 9038.00

### QUESTIONS AND ANSWERS FROM THE PRE-BID MEETING:

- Q1. Are open switch ports available in Corbett-Miller Hall?
- A1. No. The Contractor shall provide a stand-alone switch for the system.
- Q2. Are vendors other than those listed in the specifications acceptable?
- A2. Vendors other than those listed in the specifications shall submit the substitution request form found in the specifications in an effort be approved.
- Q3. Should the thumbprint reader be integrated into Windows and the active directory?
- A3. The thumbprint reader shall be integrated into Windows but NOT the active directory.
- Q4. Is the Contractor to provide the computer that hosts the door control software?
- A4. Yes, The Contractor shall provide the computer. The computer shall not be tied into the existing network however.

### **SPECIFICATIONS ITEMS:**

- 1. SECTION 00 1113 NOTICE TO BIDDERS:
  - a. In the third paragraph, CHANGE the bid date to Thursday, August 30, 2018.
- 2. SECTION 00 2113 INSTRUCTIONS TO BIDDERS:
  - a. In paragraph 3.06, CHANGE the bid date to Thursday, August 30, 2018.
- 3. SECTION 00 0107 SEALS PAGE:
  - a. REPLACE section with the attached new section which includes a signed PE stamp.
- 4. SECTION 01 1200-1.09B.1 WORK PERFORMED BY OWNER
  - a. STRIKE this paragraph and REPLACE it as follows, "The Owner shall remove each locking mechanism to allow the Contractor to terminate wiring and the Owner shall re-install each locking mechanism after the Contractor has terminated the wiring."
- 5. SECTION 28 1000-2.1A
  - a. ADD Avigilon ACM as an approved equal.

### **DRAWING ITEMS:**

- 1. DRAWING T000 COVER SHEET:
  - a. REPLACE sheet with the attached new sheet which includes a signed PE stamp.

# **ATTACHMENTS:**

- 1. Pre-Bid Meeting Sign-In Sheet
- 2. Revised Specification Section 00 0107 SEALS PAGE
- 3. Revised Drawing T000

END OF ADDENDUM

State Training School Corbett-Miller Hall Door Control Eldora, lowa

Pre-Bid Meeting August 16, 2018

Sign-in Sheet

							9						
Telephone	515. 291. 9889	319-350-9585	515. 491. 0549	641-751.5030	EE/1x EOKS-858-1/41	15-725-04SH	11-702-250-149	319.362.2760					
Email Address	TURNELE STOPPICON. COM	Chrown Ofricitye Legric. con	Zagar ico Shusstanima com	MARGE CO dhs, 5tot. 12 us 641-751 5030	Itics @ olhs. start, in us	Jenniter Keered i owar gou 1515-725- Bysy	DSMITH @ Ohs. STATE, 12.45 641-858-5402×11/6	Lbracken CC13. Com					
Company	STORY CONSTRUCTION CO.	Tri-City Electric	Blue Stone Emb	575	STS	DAS	575	C/3		,			
Name	TROY TURNER	Chris Brown	JASAN ZABAR	Mike Boegs	Jon Kies	Jenniter Kleene	BRIAN SMITH	CARL BARKER					

### **SECTION 00 0107**

### **SEALS PAGE**

I hereby certify that the portion of this technical submission described below was prepared by me or under my direct supervision and responsible charge.

Discipline: Electrical Engineer

Company Name: Bluestone Engineering, LLC

Address: 9119 Northpark Drive, Johnston, IA 50131

Telephone: 515.727.0700

Name: Kevin Bruxvoort, PE

License#: 19927

Stamp:

Responsibility: Div 28 specification sections and

AWO\

T sheets.

### **END OF SECTION**


# DEPARTMENT OF ADMINISTRATIVE SERVICES STATE OF IOWA

# STATE TRAINING SCHOOL

3211 EDGINGTON AVENUE ELDORA, IOWA 50627



DAS#9038.00









8-15-18

PROJECT NO. 118-068 SHEET SET: CONSTRUCTION

**DRAWINGS** 

**ISSUE DATE:** 08.03.18

T000