

ADDENDUM #2

Project Name: IMCC Electrical Service Upgrades

DAS# 9353.00

RFB 935300-01

Addendum #2

Dated: March 24, 2025

This Addendum forms a part of the Request for Proposal documents. This Addendum supersedes and supplements all portions of the original Request for Proposal dated February 21, 2025, with which it conflicts.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE REQUEST FOR PROPOSAL. FAILURE TO DO SO MAY SUBJECT TO DISQUALIFICATION.

1. Clarifications:

1. Sheet Series E301-E310

- a. Add general note: "Prior to installation, ensure all walls shown with new inverter(s) locations are rated to hold the weight of new inverter(s). Install all new inverters on 7/8" unistrut to distribute load across wall surface. Coordinate required wall anchors with inverter weight on final equipment cutsheets."**

2. Sheet E406 – ELECTRICAL SCHEDULES AND DETAILS

- a. Lighting Fixture Schedule: Add 'Sure-Lites' to list of approved equals.**
- b. Lighting Inverter Schedule: Add 'Emergi-Lite' to list of approved equals.**

END OF ADDENDUM