

Addendum 2 for RFB936000-02

Project Name: DOE IPBS JOH 6450 Fire Alarm Replacement

RFB #: 936000-02

DAS Project #: 9360.00

Date: 06/20/2024

BID DUE DATE JUNE 25, 2024 @ 2PM

1. QUESTIONS/ANSWERS

Q1. When it comes to changing the systems out would it be possible (to help mitigate the downtime) to get the new system up and live and as new devices come online the old ones are taken out of the old system? This would mean two systems would be running side by side for the duration of the project, until such time the old system is decommissioned.

A1. Yes, two systems can be running at the same time, if this is the case a timeline will need to be coordinated and provided to the local fire marshal.

Q2. Are all of the walls in the building stud walls with sheetrock?

A2. There is CMU for the mechanical/electrical room, production shop, exterior walls, and the mezzanine. The other walls are sheetrock in the building.