

**IOWA DEPARTMENT OF NATURAL RESOURCES
LAND & WATERS BUREAU
WALLACE STATE OFFICE BUILDING**

ADDENDUM No. 1

TRIBOJI DOCK MANAGEMENT AREA (DMA)
TRIBOJI DMA SHORELINE REPAIR & STABILIZATION
COUNTY, IOWA
PROJECT NUMBER: 25-01-30-12

July 16, 2025

This Addendum is issued to modify, explain or correct the original Drawings and Specifications, and is hereby made a part of the Contract Documents. Please attach this Addendum to the Project Manual in your possession. Insert the number and issue date of this Addendum in the blank space provided on the Proposal Form (Attachment A).

Plans:

- A. Replace Sheet D.01 with the attached revised sheet dated 7/16/25
 - a. The reference notes to the detail sheet were incorrect on the original plan and have been corrected.

Specifications:

- A. NONE

General:

- A. The trees planned for removal have been marked with a painted "X" visible from the sidewalk so contractors can better understand the scope of that work.

- TREES IDENTIFIED FOR REMOVAL SHALL BE FLUSH CUT AND REMOVED FROM THE PROJECT SITE. STUMPS SHALL BE TREATED WITH GARLON 3A OR EQUAL
- SHORELINE FLOWERS, SHRUBS, AND GRASSES WITHIN, OR ADJACENT TO THE EARTH FILL AREAS SHALL BE REMOVED PRIOR TO THE PLACEMENT OF FILL.
- EXISTING ELECTRICAL BOXES ALONG THE SHORELINE SHALL REMAIN AND BE PROTECTED FROM DAMAGE.

BEACH AREA
-THE CONTRACTOR CAN CHOOSE TO USE THE BEACH AREA FOR SHORELINE ACCESS BUT ANY DAMAGE OR RESTORATION SHALL BE INCIDENTAL TO THE CONTRACT

EXISTING SIDEWALK


- LIMIT CROSSINGS OR EQUIPMENT TRACKING TO PREVENT DAMAGE
- A PLAN FOR CROSSINGS SHALL BE PRESENTED TO THE ENGINEER FOR APPROVAL AND WILL ESTABLISH THE BASIS FOR PAYMENT ON REMOVAL AND REPLACEMENT OF DAMAGED SECTIONS
- DAMAGE ON SECTIONS NOT APPROVED SHALL BE REPLACED BY THE CONTRACTOR AT NO COST THE THE DNR

EXISTING STAIRS AND STRUCTURES (TYP)
-PROTECT EXISTING PCC STAIRWAYS FROM DAMAGE DURING CONSTRUCTION.
-WOODING STAIRWAYS IN AREAS WHERE FILL IS REQUIRED SHALL BE REMOVED BY THE OWNER PRIOR TO CONSTRUCTION. OTHERS SHALL BE PROTECTED IN PLACE.
-EXISTING BUILDINGS SHALL BE PROTECTED IN PLACE

REMOVE PCC STAIRCASE

- REPAIR SECTION B - 380' OF SHORELINE
- SALVAGE EXISTING ROCK FROM ERODED AREAS AND PREP BANK FOR FILL
- INSTALL EARTHEN FILL IN ERODED AREAS TO RE-ESTABLISH BANK SLOPES
- REGRADE SLAVAGED ROCK AND ADD NEW CLASS "E" FIELDSTONE
- REVTMENT FOR SHORELINE ARMORING
- BOTH DETAILS A & B (SHEET B.01) WILL BE UTILIZED ON THIS SECTION.
- ESTIMATED QUANTITIES
- EARTHFILL - 200 CY
- REVTMENT STONE - 200 TN
- RECP - 300SY
- SEEDING - LUMP SUM

N



ENGINEERING SERVICES
6200 PARK AVE, STE 200,
DES MOINES, IA 50312



SHORELINE REPAIR & STABILIZATION FOR:

DICKINSON COUNTY

NO.	BY DATE	REVISION
1	7/14/25	REVISED DETAIL REFERENCE
DRAWN BY:		PROJECT NUMBER: 25-01-30-12
CHK'D BY:		DATE:
SHEET No:		

D.01