

Addendum 2 for RFB927940-04

Project Name: WRC Decentralization Phase 4 & Fire Alarm Phase 3 (9279.40 & 9279.41) Bid Issuance #4
DAS RFB #: 927940-04
DAS Project #: 9279.40 & 9279.41
Date: 5/29/2026

CLARIFICATION:

Addendum #1 incorrectly changed the bid date. The bid date will remain the same Thursday June 4th, 2026 at 2:00 pm.

Bids Due: June 4, 2026, at 2:00pm

TO: PROSPECTIVE BIDDERS:

THIS ADDENDUM FORMS A PART OF THE BIDDING AND CONTRACT DOCUMENTS AND MODIFIES THE BIDDING DOCUMENTS DATED 03-27-2026, WITH AMENDMENTS AND ADDITIONS NOTED BELOW. THIS ADDENDUM SUPERSEDES AND SUPPLEMENTS ALL PORTIONS OF THE ORIGINAL BIDDING AND CONTRACT DOCUMENTS WITH WHICH IT CONFLICTS. ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE IMPACS ELECTRONIC PROCUREMENT SYSTEM. FAILURE TO DO SO MAY DISQUALIFY THE BIDDER.

QUESTIONS AND ANSWERS FROM PRE-BID MEETING

Q1. Who will be removing the security cameras and making sure the wiring is not active?

A1. The facility will handle this work.

Q2. Are there any pictures of the space above the ACT tiles?

A2. Yes, please see attachments.

Q3. Is the grading and concrete work for the units all included under BP 23-1?

A3. No, BP 23-1 is responsible for the foundations of the ductwork supports and equipment pads. BP 09-1 is responsible for grading and the remaining concrete work.

Q4. Are there any pictures of the roof at Building D where the new ductwork will be routed?

A4. Yes, please see attachments.

Q5. Is the pipe demolition in the Linden tunnel included under BP 23-1?

A5. Currently not part of this project.

CHANGES TO DRAWINGS

DRAWINGS:

- **00-E012 – ELECTRICAL SITE PLAN – LINDEN COURT**
 - **ADD** to keynote 00-E001 “FURNISH AND INSTALL NEW MAIN BREAKER RATING PLUG. PLUG TO BE CAPABLE OF ADJUSTMENT OF 0.95 TO SET THE TRIP SETTING TO 1900A.”

ATTACHMENTS

1. Photos for above the ACT ceiling.
2. Location where ductwork is routed for the AHU for building D.

END OF ADDENDUM









