

## ADDENDUM #2

**Project Name:**

**ABD ANK Boiler Replacements**

**DAS#9311.00**

**RFB931100-01**

**Dated: August 15, 2023**

This Addendum forms a part of the bidding and contract documents. This Addendum supersedes and supplements all portions of the original bidding and contract documents dated **July 14, 2023** with which it conflicts.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM. FAILURE TO DO SO MAY SUBJECT THE BIDDER TO DISQUALIFICATION.

**1. GENERAL CLARIFICATIONS**

A. Mechanical – Approved Manufacturers:

The following shall be added to specifications as approved manufacturers.

Equipment	Type	Manufacturer
25 52 16	Boilers	Camus
23 21 23	Pumps	Wilo
23 51 00	Boiler Flue	Heat Fab
23 51 00	Boiler Flue	Jeremias

**2. SPECIFICATIONS**

- A. **Section 00 1113, Notice to Bidders, Revise the following: Bid Opening** The time and place of bid opening will be held at [meet.google.com/gxt-szis-jwz](https://meet.google.com/gxt-szis-jwz) and teleconference number 731-907-2601 Pin: 784820426# at 3:00 pm on August 22<sup>nd</sup>, 2023.

**3. QUESTIONS**

- A. Will all boilers be replaced at once or will there be sequencing involved? **A> Two boilers shall always remain in service. The contractor shall have complete start-up of one new boiler prior to demolition of the next boiler and so forth.**
- B. Does the facility have space to store the new boilers while the work is being completed? **A> Yes, the mechanical room is part of a large warehouse where there is available space to store the boilers. The boilers shall be kept on pallets for easy access and moving.**

**END OF ADDENDUM**