



AIRFLOW
COMPANY

FREDERICK, MARYLAND U.S.A.

MODEL NO. CCT-6RC4-UD SER. NO. 015JD075
ELECTRICAL RATING: 460 VAC 60 HZ 3 PH
MINIMUM CLEARANCE TO COMBUSTIBLE MATERIAL: 0 IN.
COOLANT: REFRIGERANT 22
TEST PRESSURE: LOW SIDE 150 PSIG HIGH SIDE 350 PSIG
BLOWER MOTOR: 460 VAC 2.4 FLA
17 LRA 1.5 HP
COMPRESSOR(S): NO. 1 ELA LEA
NO. 2 ELA LEA
REHEAT: NO. 1 6.7 KW; NO. 2 6.7 KW; 60 HZ 3 PH AC ONLY
HUMIDIFIER HEATER: 5.8 KW; 60 HZ 3 PH AC ONLY
MINIMUM CIRCUIT AMPACITY: 33 AMPS
MAXIMUM FUSE SIZE: 35 AMPS
MAXIMUM CIRCUIT BREAKER SIZE: 35 AMPS

INSPECTOR _____

PB 220564

DATE OF MANUF. 10-31-96

**SMOKE DETECTORS AND SENSORS
MUST BE CLEANED MONTHLY.**

PB 220312



ETL LISTED

CENTRAL COOLING
AIR CONDITIONER

A0104217010

ETL TESTING LABORATORIES INC.
CORTLAND, NEW YORK 13045





CANCOIL







25x29x4
(12)

Hand Painted 8/12/15
P-1004



