

ADDENDUM #2

Project Name: DOC IMCC Fire Alarm System Replacement

DAS#9445.00

RFP944500-01

Addendum #2

Dated: January 21, 2025

This Addendum forms a part of the Request For Bids documents. This Addendum supersedes and supplements all portions of the original Request For Bids with which it conflicts.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE REQUEST FOR PROPOSAL. FAILURE TO DO SO MAY SUBJECT TO DISQUALIFICATION.

1. Questions:

- Q1. The networked fire alarm system requires a spare fiber loop to connect the buildings. Is there an available fiber loop between them?
 - A1. There is fiber at the facility in the form of Corning Multimode.

2. Drawings:

- a. None.

3. Attachments:

- a. None

END OF ADDENDUM