



Addendum #02 for RFB #918604-01

Project Name: DHS CC Strategic Space Planning Hoover 3rd Floor Dept of Admin Services

DAS RFB #: 918604-01

DAS Project #: 9186.04

Date: September 16, 2024

Addendum #2:

The original Project Manual and Drawings for the project noted above are amended as noted in this Addendum. Included in this Addendum are Specification, Architectural, & Engineering items.

Please review all sheets and incorporate them into your set of Contract Documents.

The receipt of this Addendum shall be acknowledged by inserting its number and date in the space provided on the Bid Form.

This Addendum consists of:

General Items:

1. Clarifications to project drawings keynote #1 under TELECOMMUNICATIONS DISTRIBUTION NOTES on sheet T-000 to be revised to read: DATA CABLING IS BY CONTRACTOR. PROVIDE PENETRATIONS AND PATHWAYS AS REQUIRED TO ROUTE ALL CABLING INFRASTRUCTURE ILLUSTRATED IN THE DRAWINGS. TREAT EACH NEW PENETRATION AS A 1-HOUR FIRE RATED WALL UNLESS OTHERWISE NOTED. PROVIDE REQUIRED FIRE STOPPING TO MAINTAIN THIS RATING.
2. Clarifications to project drawings keynote #3 on sheet T-103 to be revised to read: TYPICAL FOR ALL DATA LOCATIONS, CABLING IS CONTRACTOR FURNISHED OWNER INSTALLED. PROVIDE ROUGH INS AND PATHWAYS FOR ALL LOCATIONS.
3. Revised drawings sheets to be released at a later date to the awarded contractors.

END OF ADDENDUM #2