

## **ADDENDUM #3**

**Project Name:**  
**DOC IMCC Fire Alarm System Replacement**  
**DAS# 9445.00**  
**RFB 944500-02**  
**Addendum #3**  
**Dated: November 07, 2025**

This Addendum forms a part of the bidding and contract documents. This Addendum supersedes and supplements all portions of the original bidding and contract documents dated October 14, 2025 with which it conflicts.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM. FAILURE TO DO SO MAY SUBJECT THE BIDDER TO DISQUALIFICATION.

### **1) CLARIFICATIONS**

- A. The description for Alternate #3 has been updated.
  - 1. **Revise** description for Alternate #3 to the following:
    - a. Install new fire alarm cabling, conduit, and devices. Install new devices adjacent to existing. Existing fire alarm to remain intact and functional until new system has been tested and approved. Upon approval, remove existing cabling and panels in building. Existing conduit can be abandoned in place and install junction box covers on removed devices.

### **2) PLANS**

- A. No items.

### **3) QUESTIONS AND CLARIFICATIONS**

- A. No items.

### **4) SUBSTITUTION REQUESTS**

- A. No items.

### **5) ATTACHMENTS**

- A. No items.

**END OF ADDENDUM**