

Addendum #03 for RFB #0919335149

Project Name: OCIO Lucas 6th Floor Office Renovation

DAS RFB #: 0919335149

DAS Project #: 9049.00

Date: 7/17/2019

Addendum #3:

- Cover Page – Table of Contents and Clarifications(1 page)
-

Clarifications:

1. Bids Due 7/25/2019 at 2:00 pm

- Bid date has been extended to July 25, 2019
 - Question due date has been extended to July 19th at 4:00 pm
2. Doors 001A and X010B have existing card access readers. Contractor shall ensure that new auto opener hardware at 001A works with existing card readers.
 3. The existing access control panel in the west telecom closet on 6th floor has no additional capacity for new card readers.
 4. Contractor shall provide and install a new access control panel in the penthouse level for new access control at doors 001B, 002A, 002B, 002C. The existing access control panel in the penthouse is reserved for elevator use only.
 5. All new card readers are an extension of the existing Andover system and shall be fully compatible.