

Addendum 2 for RFB950800-01

Project Name: FDCF Unit A, B, & G Roof Replacement
DAS RFB #: 950800-01
DAS Project #: 9508.00
Date: 4/28/2026

QUESTIONS TO PROCUREMENT

Q1. The gauge of aluminum called out in the specifications is 0.091" thick, but no one makes that type of gauge. Can we use 0.040" thick aluminum?

A1. Please see updates to spec section 07 62 00 Sheet Metal Flashing and Trim.

CHANGES TO SPECIFICATIONS

- SECTION 07 62 00 – Sheet Metal Flashing and Trim
 - Replacement of 2.01 Sheet Metal Materials line C to read as follows.
 - C. Stainless Steel Gutters: ASTM A666/A666M, Type 304 alloy, soft temper, 18-gauge 0.050 inch thick (to match existing building F); smooth No. 4 – Brushed finish
 - Provide heavy duty reinforcement hardware / hangers as required by the gutter manufacturer.
 - Provide quantity to properly secure the gutter to the building.

END OF ADDENDUM