

## **ADDENDA #1**

**Bid Number: CCM2010006465**

**Solicitation: Ankeny Building F Replacement Boiler**

**Solicitation Type: Request for Quotes**

At vendor request we have included a floor plan of the building HVAC system. The location of the boiler is B-11 in Mechanical Room F109.

In addition to the boiler, a replacement boiler feed pump should also be included in your quote. Boiler feed pump shall be equal to or greater than Taco, 115V, 1725 RPM, Type-SS. 3.6 FLA, 1.75 SF, 4.7 SFA, 48 FR 1/6 HP CL-B3 50 AMB, Thermally Protected pump.

Please find additional information in the following attached files:

Boiler Feed Pump\_Image 1.jpg

Boiler Feed Pump\_Image 2.jpg

Boiler Feed Pump\_Image 3.jpg

Boiler Feed Pump\_Image 4.jpg

Boiler Feed Pump\_Image 5.jpg

Building F HVAC.pdf