

# **Addendum 1 for RFB949700-01**

Project Name: IMHI Warehouse Roof Replacement  
DAS RFB #: 949700-01  
DAS Project #: 9497.00  
Date: 4/16/2026

## **QUESTIONS AND ANSWERS FROM PRE-BID MEETING**

Q1. Is the hazardous materials on the canopy roof that were found supposed to be removed as part of this project?

A1. This will be handled by a separate abatement contractor and will be coordinated to be abated just before construction begins.

## **CHANGES TO DRAWINGS**

- **Sheet R0 – Level A Roof Construction Notes:**
  - Note 1. Additional cores taken indicate that core taken 45 feet + south from the west roof drain and another core taken with 2 feet of the east perimeter edge approximately 49 feet from the north edge are similar thickness/construction of the original cores noted not near the roof drain.
  - Note 2 Clarification. New tapered insulation system still required due to relatively low slope of existing assembly.

## **ATTACHMENTS**

1. Pre-Bid Meeting Sign-In sheet on 4/9/2026.

**END OF ADDENDUM**

April 9, 2026



Sign-in Sheet

Name	Company	Email Address	Telephone
Sam Vorrie	Story Construction Co.	sam.vorrie@storycon.com	515-291-4483
Darren Milliken	Story Construction Co.	darren.milliken@storycon.com	515-291-4358
Oliver Shimp	DAS	oliver.shimp@iowa.gov	515-675-4741
Mike Cook	IMHI	mcook@hhs.iowa.gov	563-608-6633
Darrell Smith	ECS Midwest	DSmith2@ecslimited.com	515-777-6765
Jett Toyne	Drspace	jett@drspace.com	319-310-6881
Bern Lyuat	Lyuat Roofing	office@lyuatroofing.com	563-920-1523
Logan Flanagan	Jim Giese Commercial	logan@jimgieseroofing.com	563-588-3699
Jeremy Siebel	Freed Cons.	Jeremy@INeedFreed.com	319-830-6922
Cam Lewis	Freed Construction	Cam@INeedFreed.com	317-239-5565
Kelly Gray	Academy Roofing	KGray@AcademyRoofing.com	515-509-5263