

## **ADDENDUM NO. 2**

Date: 2/20/24

Project Name: 9460.00 DOC NCF LU B, D and D Roof Replacement

DAS RFB #: 946000.01

DAS Project #: 9460.00

BIDS DUE: **2/25/25**

The original Project Manual and Drawings for the project noted above are amended as noted in this Addendum. Included in this Addendum are Specification, Architectural, & Engineering items.

Please review all sheets and incorporate them into your set of Contract Documents.

The receipt of this Addendum shall be acknowledged by inserting its number and date in the space provided on the Bid Form.

### **This Addendum consists of:**

#### **General Items:**

1. Crane usage will be permitted. The crane will be allowed to be placed outside of the secure fence to hoist material into and out of the secure grass area. Crane usage will only be allowed when the yard is on lock down (lock downs are scheduled daily from 11:00 am – 12:30 pm and 4:00 pm – 5:30 pm). The facility will maintain control of the key for the crane. Contractor to coordinate times for crane usage as a facility staff member will need to be with the operator during crane usage.
2. At roof penetrations the vapor barrier will need to be a minimum of 18" wide with a minimum turn up of 3" on the curb.

**End of Addendum**