

**ADDENDUM #4****Project Name: Iowa School for the Deaf (ISD) Girls Dormitory Repairs****DAS# 9356.00****RFB 935600-01****Addendum #4****Dated: October 1, 2024**

This Addendum forms a part of the bidding and contract documents. This Addendum supersedes and supplements all portions of the original bidding and contract documents dated Aug. 14, 2024 with which it conflicts.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM. FAILURE TO DO SO MAY SUBJECT THE BIDDER TO DISQUALIFICATION.

**1) CLARIFICATIONS**

A. No items.

**2) PLANS**

A. No items.

**3) SPECIFICATIONS**

A. No items.

**4) QUESTIONS & CLARIFICATIONS**

A. No items.

**5) SUBSTITUTION REQUESTS**

A. Window substitution request 3:

1. Manufacturer: Manko
2. Series: Manko 2727i
3. Substitution request is acceptable as long as it meets the following requirements: All casement windows will need to meet emergency egress requirements and fall protection requirements. This requires casement windows to open 90 degrees after release of the WOCD device. The use of any limit device that requires removal with a tool is not allowed on egress windows as per ASTM 2090.

B. See ETI's attached notes adding prior approval for Mechanical manufacturers.

**6) ATTACHMENTS**

A. ETI ASI #4 (1 page).

**END OF ADDENDUM**



DATE ISSUED

ADDENDUM #

ENGINEER

ETI PROJECT #

PROJECT

The Architect issues this Addendum to all known bidders before receipt of proposals. Bidder shall acknowledge the receipt of this addendum on their proposal sheet and all information contained herein shall become a part of the contract documents.

**ADDENDUM:**

**PRIOR APPROVAL – MECHANICAL**

1. The following manufacturers have received prior approval for bidding purposes subject to shop drawing review:
 

A. 233300 Low Leakage Control Dampers	Nailor Industries
B. 235700 Heat Exchangers for HVAC	Hexonic
C. 237223 Energy Recovery Ventilator	Aldes
D. 237223 Packaged Air-To-Air Energy Recovery Units	Nexgen
E. 238200 Convection Heating and Cooling Units	Williams Comfort Products

END OF ADDENDUM