

ADDENDUM #02

Project Name:

ABD Ankeny HVAC Controls Upgrade

DAS#9312.00

RFB931200-01

Dated: October 17, 2023

This Addendum forms a part of the bidding and contract documents. This Addendum supersedes and supplements all portions of the original bidding and contract documents dated **Sept. 8, 2023** with which it conflicts.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM. FAILURE TO DO SO MAY SUBJECT THE BIDDER TO DISQUALIFICATION.

1. GENERAL CLARIFICATIONS

- A. No items.

2. SPECIFICATIONS

- A. No items.

3. QUESTIONS

- A. Do we know what the horsepower is for the pump VFDs? **A> They are 7.5 HP pumps. Photo attached.**
- B. The addendum 01 calls out for integration of lighting and fire alarm. There is not enough information to bid this. What is the brand of lighting and fire alarm? Is it a true integration or just pulling in status and dry contacts? If it is to be integrated, is it BACnet or another type of protocol? O&M manuals and screen shots would be helpful. **A> The lighting system is an Encelium System. The Fire alarm is a Siemens system Model ZIC-4A. It is going to be true integration (see attached photos for existing system to match functionality). It is BACnet.**

4. ATTACHMENTS

- A. Photos (6 photos).

END OF ADDENDUM







