

ADDENDUM #1

Project Name:

CCF Precast Walls & Window Sealing

DAS# 9246.00

RFB 924600-01

Addendum #1

Dated: July 13, 2022

This Addendum forms a part of the bidding and contract documents. This Addendum supersedes and supplements all portions of the original bidding and contract documents dated June 10, 2022 with which it conflicts.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM. FAILURE TO DO SO MAY SUBJECT THE BIDDER TO DISQUALIFICATION.

1. BID CLARIFICATIONS

A. CHANGES TO BID SUBMITTAL AND OPENING

Please amend the above-referenced solicitation to include the following changes:

Internet Explorer 11 (IE11) desktop application was retired on June 15, 2022 and users have been redirected to use Microsoft Edge. For this reason, the Department of Administrative Services will allow email Bid submission for this Project.

Email bids to construction.prcurement@iowa.gov

**ALL BIDS MUST BE RECEIVED ON OR BEFORE 2:00PM ON THE DATE REFERENCED BELOW.
EMAILS RECEIVED AFTER 2:00PM WILL BE REJECTED.**

ELECTRONIC BIDS DUE: Tuesday, July 19, 2022 by 2:00 PM

PUBLIC OPENING:

The public opening will be held via conference call only. The call details are below.

Call time: 3:00 pm on Tuesday, July 19, 2022

Call number: 1-402-865-0133

Pin: 638 391 950#

2. SPECIFICATIONS

- A. No items.

3. DRAWINGS

- A. SHEET A1.1. ELEVATION 2 /A1.1. – Remove and reinstall the downspout cover and downspout to change the precast sealant joint on the left side of this elevation.
- B. SHEET A1.2. ELEVATION 4 /A1.2. – Remove and reinstall the downspout to change the precast sealant joint on the right side of this elevation.

4. QUESTIONS AND CLARIFICATIONS

- A. Will bids be submitted electronically like previous State of Iowa projects? A> See “Bid Clarifications” noted on this addendum for bidding procedures.
- B. Will the project allow for the contractor to work four, ten-hour days with Friday as a make up a day if there is weather that prohibits work during the first four days? A> Yes, the project can be run as four, ten-hour days. Work hours would be 7:00 am to 5:00 pm.
- C. The project schedule indicates no construction from 11-07-22 through 03-24-23, can construction continue in this period if weather allows? A> Yes, pending material installation requirements or restrictions per manufacturer's requirements. Also, temporary shelters for heating would not be allowed on this project.

5. ATTACHMENTS

- A. NONE

END OF ADDENDUM