Construction Site Inspection Checklist

Excavated Areas

- backfilled, restored, & tamped
- lawn restored
- concreted restored
- trash/debris removed

Installation Related Items

- cable/conduit at proper depth
- located within row
- markers installed

Handhole(s) Installation

- set at grade or provide depth
- crushed rock in base
- wire mesh on top of rock
- conduit(s) min. 6-in above rock
- conduit(s) plugged
- pull rope installed
- tracer wire conduit plugged
- backfilled / compacted

Cable Installation

- any visible damage to cable
- bend radius maintained
- cable properly coiled
- snap arounds installed

Locate Facilities

- ground rod installed per standards
- #6 bare copper bonded with ground clamp
- tracer wire routed into closure
- directions labeled
- locate facility tested and verified

Building Entrance/Terminations

- exterior conduit secured
- penetrations sealed
- locate facility installed (if appl)
- #10 ground to ground bar
- #10 grounded properly (lug)
- fiber panel installed correctly
- bulkhead installed correctly
- panel(s) labeled
- cable routed correctly