

## **Addendum 3 for RFB 941800-01**

Project Name: DNR Honey Creek Resort Building Automation System Improvements  
RFB#941800-01  
DAS Project #: 9418.00  
Date: 11/19/2024

**Bids Due: November 22<sup>nd</sup>, 2024 @ 2:00 PM**

### **Addendum No. 3 Items: Bid Date Changes & Clarifications**

1. Bid date & opening will be pushed back to Friday November 22<sup>nd</sup>, 2024. New times are listed below along with call in information.
  - a. Bids Due on November 22<sup>nd</sup>, 2024 at 2:00pm.
  - b. Bid Opening is on November 22<sup>nd</sup>, 2024 at 3:00pm.
    - i. Meeting link: [meet.google.com/rom-ymbt-zxb](https://meet.google.com/rom-ymbt-zxb)
    - ii. Join by phone: (US) +1 413-438-4530 PIN: 787306494
2. Additional clarification to the requested question from procurement.
  - a. Question: “Can we reuse existing sensors/control devices unless noted otherwise? What if existing sensors do not read accurately or are failed?”
  - b. Answer: All existing control sensors and devices are to be replaced, excluding control valves, VFDs, flow sensors and motorized dampers. Wiring to replaced devices can be reused if compatible with new sensors.

END OF ADDENDUM