

# **RFQ MM215820037- Preventative HVAC Maintenance** **(Boone, IA)**

## **Questions & Answers**

### **Question #1:**

In the scope of work it states VAV boxes are to be calibrated please clarify the expectations. Will someone from the building controls company or a staff member assist with this? Normally this would be part of the building automation inspection.

### **Response #1:**

PER ATTACHMENT 1: Calibrate VAV box damper and verify proper damper operation.

I apologize for our scope of work being "vague" and not going into specifics but what will be expected is that the technician that performs the inspection/maintenance is given access to the computer controls so they can properly perform the work listed as: " Calibrate VAV box damper and verify proper damper operation".