
Addendum #02 for RFP #913600-01

Project Name: IWD 150 Gate Arms

DAS RFP #: 913600-01

DAS Project #: 9136.00

Date: 11/13/2019

Addendum #2:

- Cover Page – Table of Contents and Questions

Proposals Due: **November 15th, 2019**

Questions

Q: What is the manufacturer of the existing system at 1000 E Grand Ave?

A: Global Parking Systems is the manufacturer. The model number is GPS1195. The camera system is AIPHONE IX-DA. The new gate arms at IWD 150 do not need match exactly but they should function and perform similarly to the current equipment at 1000 E Grand Ave.

Q: Please confirm the video/audio and card reader scope of work for the entrance gates.

A: There is to be one-way video at the (2) entrance gates that is viewable from the front desk. Each entrance gates shall also have a two-way audio feature that is addressable at the front desk and card reader access to open the gate directly. The card readers shall tie into the existing Andover system.

Q: Are site plans/building plans available?

A: Yes, scanned pdf plans are available of the original building that include site and electrical. PDF drawings from a 2015 project are also available. These drawings will be available to the successful design firm.

END OF ADDENDUM #2